Pellow Electrical
Testing · Inspection · Installation
3 Forge Row, Millbridge MB1 6PL

Portable Appliance Testing Certificate

Client	Larkspur Studio Ltd, Unit 4, Tannery Yard, Millbridge MB4 2TY
Date of test	3 October 2025
Next test due	**3 October 2026**
Engineer	Gareth Pellow, certificate no. PE-PAT-4471

APPLIANCES TESTED (EXTRACT)

ASSET TAG	APPLIANCE	LOCATION	CLASS	RESULT
LS-0009	Audio interface 18-in	Control room	I	**Pass**
LS-0011	Studio monitor pair	Control room	I	**Pass**
LS-0013	Mixing console 16-ch	Control room	I	**Pass**
LS-0014	Edit workstation	Edit suite	I	**Pass**
LS-0018	27" display	Design studio	I	**Pass**
LS-0020	NAS backup server	Office	I	**Pass**
LS-0021	Large-format printer	Design studio	I	**Pass**
LS-0022	LED light panel	Store room	II	**Pass**
LS-0023	LED light panel	Store room	II	**Pass**
LS-0031	Stage keyboard 88	Live room	II	**Pass**
-	Kettle	Kitchen	I	**Pass**
-	Extension leads (6)	Various	I	**Pass**

42 appliances tested, 42 passed, 0 failed. One extension lead replaced on the day (cracked plug top).

G. Pellow